

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Site: 88 cliffon rd

Location: house

Asset ID: 001	Description: washing machine	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.06	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 002	Description: tumble dryer	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	---------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.07	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 003	Description: microwave	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.06	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 004	Description: toaster	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	----------------------	-------------	--

Comments: function and visual

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
				Overall: Pass

Asset ID: 005	Description: fridge freezer	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-----------------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.1	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 006	Description: cooker	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	---------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.04	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 007	Description: tv	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-----------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.1	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 008	Description: dvd	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 009	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	10	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 010	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	10	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 011	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 012	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	--

Comments:

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 013	Description: 4 way extension	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 014	Description: 4 way extension	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.05	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Asset ID: 015	Description: 4 way extension	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.05	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 016	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 017	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Overall: Pass				

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 018	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 019	Description: hub	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 020	Description: fibre	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	--------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Earth Continuity	02/06/2025	0.1	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 021	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 022	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 023	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 024	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.07	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 025	Description: heater	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	---------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.06	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 026	Description: 2way ext	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-----------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Overall: Pass				

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.04	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 027	Description: 4 way extension	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.09	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 028	Description: 2way ext	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-----------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.08	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Asset ID: 029	Description: microwave	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.02	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 030	Description: toaster	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	----------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.1	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 031	Description: kettle	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	---------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Asset ID: 032	Description: fridge freezer	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-----------------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	10	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 033	Description: Hoover	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	---------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 034	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	--

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Asset ID: 035	Description: oven	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	< 0.010	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 036	Description: cabinet light	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	----------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.05	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 037	Description: cabinet light	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	----------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	10	Amp	Information

Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 038	Description: fan	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 039	Description: 2 way ext	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	------------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	13	Amp	Information
Earth Continuity	02/06/2025	0.07	ohm	Pass
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
				Overall: Pass

Asset ID: 040	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
				Overall: Pass

Detailed Latest Test Results



SEAWARD
ELECTRICAL SAFETY TESTING & MEASURING

Test Status: All, Test Type: All
Person: All, Instrument: All
From: 20/05/2025 To: 23/06/2025

Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 041	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 042	Description: lamp	User: admin	Test Instrument: Seaward Apollo 500 29H-0095
---------------	-------------------	-------------	---

Comments:

Test Type	Date	Result	Unit	Status
Plug	02/06/2025			Pass
Flex	02/06/2025			Pass
Enclosure	02/06/2025			Pass
Environment	02/06/2025			Pass
Socket	02/06/2025			Pass
Switch	02/06/2025			Pass
Voltage	02/06/2025	230	V	Information
Fuse Rating	02/06/2025	3	Amp	Information
Insulation Voltage	02/06/2025	500	V	Information
Insulation	02/06/2025	> 19.99	MOhm	Pass
Overall: Pass				

Total Tests: 42